

			I SEMESTRE 2026									
Parametro analizzato	Unità di misura	Limite di legge	Isola Morosini	Gorizia	Farra	Cormons	Dolegna	Monfalcone	Ronchi dei Legionari	San Canzian d'Isonzo	Grado	San Pier d'Isonzo
BICARBONATI	mg/l	-	246.00	255.00	190.00	428.00	226.00	200.00	203.00	227.00	193.00	188.00
AMMONIO	mg/l	<0,5	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02	<0.02
ARSENICO	µg/l	<10	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00	<1.00
CALCIO	mg/l	-	58.20	65.20	53.80	97.00	64.20	63.20	54.00	57.70	49.00	51.90
CLORURO	mg/l	<250	5.17	5.78	3.91	5.29	3.29	14.80	3.56	3.78	9.40	12.10
CONCENTRAZIONE IONI IDROGENO	unità pH a 20°C	6.5 ÷ 9.5	7.70	7.70	7.80	7.30	8.00	7.60	7.70	7.80	7.90	7.80
CONDUTTIVITA`	µS/cm a 20°C	<2500	425.00	368.00	295.00	518.00	404.00	370.00	315.00	341.00	311.00	334.00
DUREZZA TOTALE	°f	-	24.40	22.00	17.60	29.80	23.20	21.20	17.90	19.80	17.20	17.90
FLUORURO	mg/l	<1,5	<0.10	<0.10	<0.10	<0.10	0.11	<0.10	<0.10	<0.10	<0.10	<0.10
MAGNESIO	mg/l	-	23.90	14.00	10.10	13.80	17.40	13.20	10.70	13.10	11.90	11.90
MANGANESE	µg/l	<50	<5.00	<5.00	<5.00	<5.00	<5.00	<5.00	<5.00	<5.00	<5.00	<5.00
NITRATO (COME NO3)	mg/l	<50	15.40	6.40	4.10	14.40	3.70	8.00	5.50	7.60	5.80	6.40
NITRITO (COME NO2)	mg/l	<0,1	<0.03	<0.03	<0.03	<0.03	<0.03	<0.03	<0.03	<0.03	<0.03	<0.03
POTASSIO	mg/l	-	0.67	1.12	0.58	2.44	0.70	0.84	0.71	0.90	0.70	0.72
RESIDUO FISSO A 180°C	mg/l	-	258.00	248.00	74.00	204.00	162.00	224.00	58.00	124.00	102.00	206.00
SODIO	mg/l	<200	4.07	2.86	2.68	4.53	2.76	8.09	2.33	2.58	6.00	6.92
SOLFATO	mg/l	<250	23.40	14.00	8.30	12.90	74.40	11.70	8.70	9.40	9.80	10.50
CLORO RESIDUO	mg/l	<0,2	-	0.08	0.12	0.12	0.02	0.09	0.01	0.04	0.06	0.01